

Government of West Bengal
Irrigation & Waterways Directorate
Office of the Superintending Engineer, Mechanical & Electrical Circle
Jalasampad Bhawan (6th Floor),
Bidhannagar, Kolkata – 700 091 Phone No. 033-23218430
Fax No. 03323218430 E-Mail ID : semeciwd2017@gmail.com

Date: 01.10.2018

Memo No: 1404 /1T-6

CLARIFICATION OF POINTS RAISED BY BIDDER(S) DURING 2ND PRE BID MEETING
HELD ON 28.09.2018

e-RFP No. WBIW/SE/MEC/RFP-03(e)/2018-19

e-Tender ID: 2018_IWD_189485_1

Name of work : “Providing, Installation, Testing & Commissioning of Intelligent addressable fire detection and alarm system for Jalasampad Bhawan Govt office Complex comprising 3 (three) Building blocks at DF Block, Sector-I, Bidhannagar, 700091, District- North 24- Parganas.”

The following clarifications has been made against the points raised by the bidder(s) during pre bid meeting held on 28.09.2018.

Sl no	Points Raised by Bidder(s)	Clarifications
1	No of devices as per B.O.Q against item sl. No.2.0	For minimum no of detector ,please refer point 16&17 of Technical specification under sub head 1.2.1.2 .Nos. of devices per loop length are to be considered as per system design as approved by E.I.C.
2	Against B.O.Q , item sl. No.4.0	Please consider 18.5 inch monitor, PC (core i7) , printer , with original software , as approved by E.I.C.
3	Against B.O.Q , item sl. No.9.0	Control module is inclusive with this item .
4	Against B.O.Q , item sl. No.15.0 & 18.0	No of zone to be considered as per system requirement as approved by E.I.C.
5	Against B.O.Q , item sl. No.17.0	Amplifier wattages are to be considered as per system requirement as approved by E.I.C.
6	Regarding IP standard in technical specification	Please ignore IP standard for indoor equipment
7	Clause 13.1 of technical specification	Pl. ignore the clause , follow B.O.Q item description.
8	In technical specification , regarding NFPA /EN standard	Please consider NFPA/EN/UL/ULC approved standard.
9	Against B.O.Q , item sl. No.10.0	Please consider unarmored cable.

S. M.
 Superintending Engineer
 Mechanical & Electrical Circle
 Irrigation & Waterways Directorate

01/10/18
ex-10.18

Government of West Bengal
Irrigation & Waterways Directorate
Office of the Superintending Engineer, Mechanical & Electrical Circle
Jalasampad Bhawan (6th Floor),
Bidhannagar, Kolkata – 700 091 Phone No. 033-23218430
Fax No. 03323218430 E-Mail ID : semeciwd2017@gmail.com

Memo No: 1405/1T-6

Date: 01.10.2018

1st CORRIGENDUM

e-RFP No. WBIW/SE/MEC/RFP-03(e)/2018-19

e-Tender ID: 2018_IWD_189485_1

Name of work : Providing, Installation ,Testing & Commissioning of Intelligent addressable fire detection and alarm system for Jalasampad Bhawan Govt Office Complex comprising 3 (three) Building blocks at DF-Block, Sector-I, Bidhannagar, 700091, District-North 24-Parganas.

The following modifications are made for this e-RFP with immediate effect.

1. Schedule of Critical dates of this e-RFP (Sl no 26, page no 19 of the published e-RFP)


Sl. No	Activity sl no as already published	Activity	Existing Date & Time	Latest Date & Time Modified by corrigendum	Remarks
1	5.	Document Download end date & bid submission end date	09/10/2018 at 17.00 Hrs	29/10/2018 at 17.00 Hrs	To be viewed in the website https://wbtenders.gov.in
2	6.	Bid submission end date	09/10/2018 at 17.00 Hrs	29/10/2018 at 17.00 Hrs	-Do-
3	7.	Technical Bid opening date	10/10/2018 at 11.00 Hrs	30/10/2018 at 11.00 Hrs	-Do-

2. Acceptable Make of this e-RFP:

SL No.	ITEM	Existing Acceptable Make	Modified Acceptable Make
1.	Fire Control Panel	Honeywell (Notifier) / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
2.	Repeater Panel	Honeywell (Notifier) / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
3.	Thermal Heat Detector	Honeywell (Notifier), / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
4.	Multi sensor Detector	Honeywell (Notifier) / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
5.	Addressable Manual Call Point	Honeywell (Notifier) / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
6.	Remote Indicator	AGNI/ Reputed Make	AGNI/ Reputed Make
7.	Addressable Sounder cum strobe	Honeywell (Notifier) / Eaton/ Edwards/Siemens, Bosch, approved make	Honeywell /Siemens/ Bosch / UTC fire
8.	FRLS Copper Cable	Finolex/ Gloster/ Mescab/ approved make	Finolex/ Gloster/ Mescab/ approved make
9.	PVC Rigid conduit pipe	Precision/ approved make	Precision/ approved make
10	PA CONSOLE	Ahuja/ Bosch/Seimens/ approved make	Bosch/ Honeywell / heinrich
11	WALL/CEILING Mounted Speaker	Ahuja/ Bosch/Seimens/ approved make	Bosch/ Honeywell / heinrich

Other terms and conditions of this eRFP remains unchanged.

(Reference: Memorandum no 3661-F(Y) Dated. 7th June, 2018 of Additional Chief Secretary to the Government of West Bengal).


 Superintending Engineer
 Mechanical & Electrical Circle
 Irrigation & Waterways Directorate
 01/10/18
 et-10-18