



Government of West Bengal
Irrigation & Waterways Directorate
Office of the Executive Engineer
Metropolitan Drainage Mechanical Division
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Telephone No-03323345768, Email Id: mdmdiwd@gmail.com

Memo No.- 305/6E-II/22-23

Date:- 10/03/2023

CORRIGENDUM

for

EoI No.: WBIW/EE/MDMD/EoI-03/2022-23

NOTICE INVITING

EXPRESSION OF INTEREST (EoI)

For

Supply, installation, testing and commissioning including trial run and one year successful operation and maintenance of external water lubricated Vertical Turbine pump sets four (04) nos. 50 cusec with electro-mechanical installation complete for the proposed pumping station at the outfall of cantonment khal, Dist- North 24 PGS ,West Bengal .

Government of West Bengal
Irrigation & Waterways Directorate
Office of the Executive Engineer
Metropolitan Drainage Mechanical Division
Jalasampad Bhawan (4th floor), Salt Lake City, Kolkata-91
Telephone No-03323345768, Email Id: mdmdiwd@gmail.com


CORRIGENDUM

for

EoI No.: WBIW/EE/MDMD/EoI-03/2022-23

The following corrigenda are made in connection with the above EoI.

1. The participants may also submit their scan copy of bid with all necessary documents along with the covering letter duly signed by an authorized signatory by email at the id: **mdmdiwd@gmail.com**
2. The Last date and time for bid Submission: 20.03.2023 **17:00 Hrs.**
3. **Revised Eligibility Criteria:**
 - i) Offering of rate for Pump & motor : Any OEM/Authorized dealer of VT Pump or OEM/Authorized Rs.880585.00 dealer of Electrical motor or any agency having experience of successful SITC of at least one pump-motor set of 50 Cusec capacity in last 5 years is acceptable.
 - ii) Offering of rate for mechanical items is acceptable for above stated sources (under Sl no. 3 i) or any other agency having experience of similar mechanical works viz and installation of Trash rack/Screen, Bore well etc of value more than 40.00 Lac in single order in last 5 years.
 - iii) Offering of rate for electrical items is acceptable for above stated sources (under Sl no. 3 i) or any other agency having experience of similar electrical works viz SITC of HT/LT/Capacitor Bank Panels, Transformer, Cables etc of value more than 40.00 Lac in single order in last 5 years.
 - iv) Offering of rate for EOT/Monorail hoist is acceptable for above stated sources (under Sl no. 3 i) or any other OEM/agency having experience of similar works in last 5 years.
4. In the Schedule of works (B.O.Q) Item SL no. 2, Motor rating should be atleast 132KW in place 125KW. The bidder can offer any higher rating as per design requirements.
5. In the Schedule of works (B.O.Q) Item SL no. 19, LT Panel at Pump House, rating of all Air circuit breaker (ACB) should be at least 1250A in place of 1000A.
6. In the Schedule of works (B.O.Q) Item SL no. 20, Consumer 1 Panel ACB at Substation, rating of Air circuit breaker (ACB) should be at least 1250A in place of 1000A.
7. All other data, information's, terms & conditions will remain unchanged.


Executive Engineer

Metropolitan Drainage Mechanical Division